

BOSE INSTITUTE
Centenary Building,
P-1/12, CIT Scheme – VII M, Kankurgachi,
Kolkata – 700 054 (INDIA)

Minutes of the Pre-bid Conference held on 15.10.2019 at 12.00 noon in the Seminar room of the Department of Biochemistry regarding Tender Notice No. BI-K/E-TEND/13/2019-20 with tender id : 2019_BIK_508395_1 for *Procurement of Furniture and other items for Laboratories at UAC*

Members present :

- Prof. Sujoy DasGupta
- Prof. T.P. Sinha
- Dr. Jayanta Mukherjee
- Dr. Ajit Bikram Datta
- Dr. Kaushik Biswas
- Dr. Anirban Bhunia
- Dr. Shubho Chaudhuri
- Dr. Atin Paul
- Dr. Smarajit Polley
- Mr. Sougato Banerjee
- Mr. Raju Ch Paul
- Mr. Sumanta Ghosh
- Mrs. Babli Marrick

Bidders present ::

- Representative of M/s Stellar Furniture
- Representative of M/s Kewaunee Labway India Pvt. Ltd.
- Representative of M/s Citizen Industries

Resolution of the Pre-bid Conference

| Existing specification | Amended specification in the relevant portion to be read as |
|---|--|
| 1. Chapter 1 Part D – Sl. No. 6 (D) - Capacity: 2 cylinders Chapter 1 Part D – Sl. No. 6 (F) - Gas manifold should be inside the gas cabinet, regulator, Automatic changeover & amp; accessories | 1. To be read as – Capacity: 2 cylinders of volume 47 litres with dimension 153 cm (H) x 22 cm (Diameter) To be read as – The cabinet should have the provision to install the gas distribution system consisting of the gas manifold, regulator, and automatic changeover inside it. |

| Existing specification | Amended specification in the relevant portion to be read as |
|---|---|
| <p>2. SOQ Supply</p> <ul style="list-style-type: none"> • Sl. No. 6.11 6/13A 2 Gang DP Switch Socket Outlet (230V) • SOQ Supply Sl. No. 7.08 6/13A 2 Gang DP Switch Socket Outlet (230V) • SOQ Supply Sl. No. 8.16 13A 2 Gang DP Switch Socket Outlet (230V) | <p>2. To be read as –</p> <p>SOQ_SUPPLY item Nos listed in 6.11, 7.08 and 8.16 the description should be read as</p> <p>“6/13A gang two switch two universal 3-pin socket module”</p> |
| <p>3. SOQ Installation : Contract No. BI-K/E-TEND/04/2019-20</p> | <p>3. To be read as – SOQ Installation : Contract No. : BI-K/E-TEND/13/2019-20</p> |
| <p>4. INSTRUCTION FOR FILLING UP THE PRICE-BID (BOQ/SOQ)</p> <p>(d) Fill up the Freight and Insurance charges (up to Bose Institute, Kolkata) row (#153) in “SOQ_SUPPLY” only if the prices are quoted in a currency other than INR.</p> | <p>4. INSTRUCTION FOR FILLING UP THE PRICE-BID (BOQ/SOQ)</p> <p>To be read as - row (#148) in “SOQ_SUPPLY” instead of row 153</p> |
| <p>5. Invitation to Bids - Page No. 2 Sl. No. 13. “ Date of uploading the final list of Technically Qualified Bidder (online) after disposal of appeals, if any.</p> | <p>Page No. 2 Sl. No. 13 to be ignored</p> |

Registrar (Officiating)